

STEVEN L. BESHEAR GOVERNOR

ENERGY AND ENVIRONMENT CABINET

LEONARD K. PETERS
SECRETARY

DEPARTMENT FOR ENVIRONMENTAL PROTECTION
DIVISION OF WATER
200 FAIR OAKS LANE
FRANKFORT, KENTUCKY 40601-1190
www.kentucky.gov

FACT SHEET

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT TO DISCHARGE TREATED WASTEWATER INTO WATERS OF THE COMMONWEALTH

KPDES No.: KY0066931 Permit Writer: Diana Davidson Date: September 2, 2009

AI No.: 915

1. SYNOPSIS OF APPLICATION

a. Name and Address of Applicant

Girl Scouts of Kentuckiana, Incorporated 2115 Lexington Road Louisville, Kentucky 40206

b. Facility Location

Pennyroyal Girl Scout Camp 3095 Girl Scout Road Utica, Daviess County, Kentucky

c. Description of Applicant's Operation

Recreational Camp

d. Design Capacity

0.005 MGD

e. Description of Existing Pollution Abatement Facilities

Treatment consists of sedimentation/settling, chlorine disinfection, activated sludge, discharge to surface water, and the pumped out sludge is hauled to a larger local publicly owned treatment works.



KPDES No.: KY0066931

AI No.: 915 Fact Sheet Page 2

f. Permitting Action

This is a reissuance of a minor KPDES permit for a wastewater treatment plant serving a recreational camp.

2. **RECEIVING WATER**

a. Name/Mile Point

Facility discharges to an unnamed tributary to an unnamed tributary of North Fork Barnett Creek at latitude 37° 35' 54'' and longitude 87° 01' 30''.

b. Stream Segment Use Classification

Pursuant to 401 KAR 10:026, Section 5, the unnamed tributary to an unnamed tributary of North Fork Barnett Creek carries the following classifications:

Warmwater Aquatic Habitat, Primary/Secondary Contact Recreation, and Domestic Water Supply

c. Stream Segment Categorization

Pursuant to 401 KAR 10:030, Section 1, the unnamed tributary to an unnamed tributary of North Fork Barnett Creek is categorized as a High Quality Water.

d. Stream Low Flow Condition

The 7-day, 10-year low flow condition of the unnamed tributary to an unnamed tributary of North Fork Barnett Creek is 0.00 cfs.

KPDES No.: KY0066931

AI No.: 915
Fact Sheet Page 3

3. REPORTED DISCHARGE AND PROPOSED LIMITS

Serial Number 001 - Sanitary Wastewater (Design Flow = 0.005 MGD)

Effluent Characteristics	Reported Dia Monthly Average	scharge Daily Maximum	Proposed Monthly Average	Limits Daily Maximum	Applicable Water Quality Criteria and/or Effluent Guidelines
Flow (MGD)	0.0012	0.0028	Report	Report	401 KAR 5:065, Section 2(8)
$CBOD_5$ (mg/1)	4.10	4.14	30	45	401 KAR 10:031, Section 4 401 KAR 5:045, Sections 3 and 5
TSS (mg/l)	23.00	26.43	30	45	401 KAR 10:031, Section 4 401 KAR 5:045, Sections 2 and 3
Fecal Coliform (N/100 ml)	9.85	10.59	Removing f	rom permit	401 KAR 5:080, Section 1(2)(c)2
Escherichia Coli (N/100 ml)	NR	NR	130	240	401 KAR 10:031, Section 7 401 KAR 5:045, Section 4 401 KAR 5:080, Section 1(2)(c)2
Ammonia Nitrogen (as mg/l N) May 1 - October 31 November 1 - April 30	2.13 0.67	2.13 0.67	4.0	6.0 15	401 KAR 10:031, Section 4 401 KAR 5:045, Sections 3 and 5
Dissolved Oxygen (mg/l) (minimum)	7.91	N/A	Not less t	than 7.0	401 KAR 10:031, Section 4 401 KAR 5:045, Sections 3 and 5
pH (standard units)	5.82	7.8	6.0 (min)	9.0 (max)	401 KAR 10:031, Section 4 401 KAR 5:045, Section 4
Total Residual Chlorine (mg/l)	NR	NR	0.011	0.019	401 KAR 10:031, Section 4(k)

The data contained under the reported discharge columns is not from the renewal application, but rather from the analysis of the DMR data that has been reported during the term of the previous permit.

The abbreviation CBOD₅ means Carbonaceous Biochemical Oxygen Demand (5-day).

The abbreviation TSS means Total Suspended Solids.

The abbreviation NR means not reported on the Discharge Monitoring Report (DMR).

The effluent limitations for CBOD₅ and TSS are Monthly (30 day) and Weekly (7 day) Averages.

The effluent limitations for Escherichia Coli are thirty (30) day and seven (7) day Geometric Means.

KPDES No.: KY0066931 AI No.: 915 Fact Sheet Page 4

METHODOLOGY USED IN DETERMINING LIMITATIONS 4.

Serial Number

Outfall 001 Sanitary Wastewater (Design Flow = 0.005 MGD)

b. Effluent Characteristics

> Flow, CBOD₅, TSS, Fecal Coliform Bacteria, Escherichia Coli, pH, Ammonia Nitrogen, Dissolved Oxygen, and Total Residual Chlorine (TRC).

С. Pertinent Factors

None

d. Monitoring Requirements

Flow monitoring shall be conducted instantaneously once per quarter.

CBOD₅, TSS, Ammonia Nitrogen, shall be monitored once per quarter by 12 hour composite sampling.

Escherichia Coli, pH, Dissolved Oxygen and Total Residual Chlorine shall be monitored once per quarter by grab sample.

e. Justification of Conditions

The Kentucky regulations cited below have been duly promulgated pursuant to the requirements of Chapter 224 of the Kentucky Revised Statutes.

Escherichia Coli and Fecal Coliform Bacteria

The limits for Escherichia Coli are consistent with the requirements of 401 KAR 10:031, Section 7, 401 KAR 5:045 Section 4 and 401 KAR 5:080, Section 1(2)(c) 2. The removal of Fecal Coliform Bacteria is consistent with the requirements of 401 KAR 5:080k Section 1 (2) (c)2. Although Fecal Coliform Bacteria has been used as an indicator of fecal contamination, it does contain other species that are not necessarily fecal in origin. recommends Escherichia Coli, which is specific to fecal material from warmblooded animals, as the best indicator of health risk from contact with recreational waters. Therefore, it is the "Best Professional Judgment "BPJ" of the Division of Water that Escherichia Coli replace Fecal Coliform Bacteria on this permit.

The monitoring requirements for this parameter are consistent with the requirements of 401 KAR 5:065, Section 2(8).

CBOD₅, Ammonia Nitrogen, and Dissolved Oxygen

The limits for these parameters are consistent with the requirements of 401 KAR 10:031, Section 4, and 401 KAR 5:045, Sections 3 and 5. Section 4 of 5:031 establishes water quality criteria for the protection of Kentucky's waters. Section 5 of 5:045 requires biochemically degradable wastewaters to receive treatment in excess of secondary treatment if the Cabinet determines that the receiving water would not satisfy applicable water quality standards as a result of a facility discharge or discharges from multiple facilities.

KPDES No.: KY0066931 AI No.: 915

Fact Sheet Page 5

Total Suspended Solids

The limits for this parameter are consistent with the requirements of 401 KAR 10:031, Section 4 and 5:045, Sections 2 and 3. Section 4 of 10:031 establishes water quality criteria for the protection of Kentucky's waters. Sections 2 and 3 of 5:045 require biochemically degradable wastewaters to receive secondary treatment.

Нq

The limits for these parameters are consistent with the requirements of 401 KAR 10:031, Section 4 and 5:045, Section 4. Section 4 of 10:031 establishes water quality criteria for the protection of Kentucky's waters. Section 4 of 5:045 establishes the acceptable levels of these parameters for biochemically degradable wastewaters.

Total Residual Chlorine

The limits for these parameters are consistent with the requirements of 401 KAR 10:031, Section 4.

5. **ANTIDEGRADATION**

The conditions of 401 KAR 10:029, Section 1 have been satisfied by this permit action. Since this permit action involves reissuance of an existing permit, and does not propose an expanded discharge, a review under 401 KAR 10:030 Section 1 is not applicable.

6. PROPOSED COMPLIANCE SCHEDULE FOR ATTAINING EFFLUENT LIMITATIONS

The permittee will comply with all effluent limitations by the effective date of the permit.

7. PROPOSED SPECIAL CONDITIONS WHICH WILL HAVE A SIGNIFICANT IMPACT ON THE DISCHARGE

Disposal of Non-Domestic Wastes

The pass through or non-treatment by the wastewater treatment plant of chemicals or compounds which may injure, be chronically or acutely toxic to or produce adverse physiological or behavioral responses in humans, animals, fish and other aquatic life is not desirable. Materials such as acids, caustics, herbicides, household chemicals or cleansers, insecticides, lawn chemicals, non-biodegradable products, paints, pesticides, pharmaceuticals, and petroleum based products may not be treatable by the wastewater treatment plant and should not be introduced and other environmentally sound methods for disposal should be utilized. The permittee should educate users of its system that introduction of such chemicals or compounds could result in an adverse environmental impact and provide the users with alternative disposal measures. This requirement is consistent with the requirements of 401 KAR 5:065, Section 1(5) and 401 KAR 5:080, Section 1(c)(2)c.

KPDES No.: KY0066931 AI No.: 915 Fact Sheet Page 6

Certified Operators

Pursuant to 401 KAR 5:010, Section 1 wastewater systems shall be operated under the supervision of a certified operator who holds a Kentucky Certificate equivalent to the class of system being supervised.

Pursuant to 401 KAR 5:010, Section 3 the certified operator shall be reasonably available if not physically present while the system is operating.

Outfall Signage

It is the Best Professional Judgment of the Division of Water, 401 KAR 5:080, Section 1(2)(c)2, that all permittees post a marker at all discharge locations and/or monitoring points. The marker shall be of sufficient size to display the Permittee Name, KPDES permit and outfall numbers in 2 inch letters and shall be prominently displayed. For internal monitoring points the marker shall be of sufficient size to include the outfall number in 2 inch letters and is to be posted as near as possible to the actual sampling location.

8. **PERMIT DURATION**

Five (5) years. This facility is in the Tradewater, Green Basin Management Unit as per the Kentucky Watershed Management Framework.

9. **PERMIT INFORMATION**

The application, draft permit, fact sheet, public notice, comments received, and additional information is available from the Division of Water at 200 Fair Oaks Lane, Frankfort, Kentucky 40601.

10. REFERENCES AND CITED DOCUMENTS

All material and documents referenced or cited in this fact sheet are a part of the permit information as described above and are readily available at the Division of Water Central Office. Information regarding these materials may be obtained from the person listed below.

11. CONTACT


For further information on the draft permit or comment process, contact the individual identified on the Public Notice or the Permit Writer - Diana Davidson at (502) 564-8158, extension 4901, or email Diana.Davidson@ky.gov.


12. PUBLIC NOTICE INFORMATION

Please refer to the attached Public Notice for details regarding the procedures for a final decision, deadline for comments and other information required by 401 KAR 5:075, Section 4(2)(e).

KPDES No.: KY0066931

AI No.: 915 Fact Sheet Page 7





PERMIT NO.: KY0066931 **AI NO.:** 915

AUTHORIZATION TO DISCHARGE UNDER THE KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM

Pursuant to Authority in KRS 224,

Girl Scouts of Kentuckiana, Incorporated 2115 Lexington Road Louisville, Kentucky 40206

is authorized to discharge from a facility located at

Pennyroyal Girl Scout Camp 3095 Girl Scout Road Utica, Daviess County, Kentucky

to receiving waters of an

Unnamed tributary of North Fork Barnett Creek at latitude 37° 35′ 54″ and longitude 87° 01′ 30″

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, III, and IV hereof. The permit consists of this cover sheet, and Part I $\underline{2}$ pages, Part II $\underline{1}$ pages, and Part III $\underline{1}$ page.

This permit shall become effective on.

This permit	and t	he autho	rization	to disc	charge	shall	expire	at	midnight,
4	1								
		A A							
Date Signed				Sa	ndra L.	Gruze	esky, Di	rec	tor
2222 3291104					rigion				

PART I Page I-1

Permit No.: KY0066931

AI No.: 915

PART I A - EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning on the effective date of this permit and lasting through the term of this permit, the permittee is authorized to discharge from Outfall serial number: 001 - Sanitary Wastewater (Design Flow = 0.005 MGD)

Such discharges shall be limited and monitored by the permittee as specified below:

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS			MONITORING REQUIREMENTS		
	(lbs/	day)	Other Units (Other Units (Specify)		
	Monthly	Daily	Monthly	Daily	Measurement	Sample
	Avg.	Max.	Avg.	Max.	<u>Frequency</u>	Type
Flow (MGD)	Report	Report	N/A	N/A	1/Quarter	Instantaneous
$CBOD_5$ (mg/l)	1.25	1.94	30	45	1/Quarter	12 Hr Composite
TSS (mg/l)	1.25	1.94	30	45	1/Quarter	12 Hr Composite
Ammonia Nitrogen (as mg/l N)						
May 1 - October 31	0.17	0.25	4.0	6.0	1/Quarter	12 Hr Composite
November 1 - April 30	0.42	0.62	10	15	1/Quarter	12 Hr Composite
Escherichia Coli (N/100 ml)	N/A	N/A	130	240	1/Quarter	Grab
Dissolved Oxygen (mg/l) (minimum)	N/A	N/A	Not less than		1/Quarter	Grab
pH (standard units)	N/A	N/A	6.0 (min)	9.0 (max)	1/Quarter	Grab
Total Residual Chlorine (mg/l)	N/A	N/A	0.011	0.019	1/Quarter	Grab

The abbreviation CBOD₅ means Carbonaceous Biochemical Oxygen Demand (5-day).

The abbreviation TSS means Total Suspended Solids.

The abbreviation N/A means Not Applicable.

The effluent limitations for CBODs and TSS are Monthly (30 day) and Weekly (7 day) Averages.

The effluent limitations for Escherichia Coli are thirty (30) day and seven (7) day Geometric Means.

There shall be no discharge of floating solids or visible foam or sheen in other than trace amounts.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location: nearest accessible point prior to discharge to or mixing with the receiving waters or wastestreams from other outfalls.

PART I Page I-2

Permit No.: KY0066931 AI No.: 915

PART I B - SCHEDULE OF COMPLIANCE

The permittee shall achieve compliance with all requirements on the effective date of this permit.



PART II Page II-1

Permit No.: KY0066931

AI No.: 915

PART II - STANDARD CONDITIONS FOR KPDES PERMIT

This permit has been issued under the provisions of KRS Chapter 224 and regulations promulgated pursuant thereto. Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits or licenses required by this Cabinet and other state, federal, and local agencies.

It is the responsibility of the permittee to demonstrate compliance with permit parameter limitations by utilization of sufficiently sensitive analytical methods.

The permittee is also advised that all KPDES permit conditions in KPDES Regulation 401 KAR 5:065, Section 1 will apply to all discharges authorized by this permit.

PART III Page III-1

Permit No.: KY0066931

AI No.: 915

PART III - OTHER REQUIREMENTS

A. Reporting of Monitoring Results

Monitoring results obtained during each monitoring period must be reported on a preprinted Discharge Monitoring Report (DMR) Form that will be mailed to you. The completed DMR for each monitoring period must be sent to the Division of Water at the address listed below (with a copy to the appropriate Regional Office) postmarked no later than the 28th day of the month following the monitoring period for which monitoring results were obtained.

Division of Water Madisonville Regional Office 625 Hospital Drive Madisonville, Kentucky 42431-1683 ATTN: Supervisor Division of Water Surface Water Permits Branch Permit Support Section 200 Fair Oaks Lane Frankfort, Kentucky 40601

B. Reopener Clause

This permit shall be modified, or alternatively revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under 401 KAR 5:050 through 5:086, if the effluent standard or limitation so issued or approved:

- 1. Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- 2. Controls any pollutant not limited in the permit.

The permit as modified or reissued under this paragraph shall also contain any other requirements of KRS Chapter 224 when applicable.

C. Disposal of Non-Domestic Wastes

The pass through or non-treatment by the wastewater treatment plant of chemicals or compounds which may injure, be chronically or acutely toxic to or produce adverse physiological or behavioral responses in humans, animals, fish and other aquatic life is not desirable. Materials such as acids, caustics, herbicides, household chemicals or cleansers, insecticides, lawn chemicals, non-biodegradable products, paints, pesticides, pharmaceuticals, and petroleum based products may not be treatable by the wastewater treatment plant and should not be introduced and other environmentally sound methods for disposal should be utilized. The permittee should educate users of its system that introduction of such chemicals or compounds could result in an adverse environmental impact and provide the users with alternative disposal measures.

D. Certified Operators

This wastewater system shall be operated under the supervision of a Class I Kentucky Certified Operator who shall be reasonably available at all times. All other operators employed by the system shall hold a Kentucky Certificate or shall be in the process of obtaining a Kentucky Certificate. The certificates of each operator shall be prominently displayed on the wall of the system office.

E. Outfall Signage

The permittee shall post a permanent marker at all discharge locations and/or monitoring points. The marker shall be at least 2 feet by 2 feet in size and a minimum of 3 feet above ground level with the Permittee Name and KPDES permit and outfall numbers in 2 inch letters. For internal monitoring points the marker shall be of sufficient size to include the outfall number in 2 inch letters and shall be posted as near as possible to the actual sampling location.